

# tSENSE (Disp)



## CO<sub>2</sub>, Temperature and RH Sensor with colour touch display

tSENSE is an advanced and versatile 3-in-1 sensor designed for installation in the air-conditioned zone. It measures CO<sub>2</sub> concentration, temperature and humidity in the ambient air accurately without need for additional compensation – true read. The data transmits to a BMS system or stand-alone controller using industry standard output signals and communication protocols.

tSENSE combines all the necessary elements for effective climate control in commercial office buildings, hospitals, hotels, schools and other facilities. Using CO<sub>2</sub>-monitoring for demand control ventilation (DCV) allows healthy, comfortable and cost-effective environment for the occupants.

tSENSE is flexible in design with temperature control in combination with humidity control optional. Though suitable for use in many different energy-efficient ventilation strategies, Senseair welcomes any discussions for specific needs.

Complies with ASHRAE standard 189.1  
(±50ppm @ 1000ppm of measured CO<sub>2</sub> value)

## Standard specification

|                             |   |
|-----------------------------|---|
| Measured gas                | Carbon dioxide (CO <sub>2</sub> )                         |
| Operating principle         | Non-dispersive infrared (NDIR)                            |
| Measurement range           | 0–2000ppm   |
| OUT1 CO <sub>2</sub>        | 0–10VDC, 0–2000ppm  |
| OUT2 Temperature            | 0–10VDC, 0–50°C   |
| OUT3 Relative Humidity      | 0–10VDC, 0–100%RH   |
| Relay CO <sub>2</sub>       | On ≥1000 ppm <sub>vol</sub><br>Off ≤900ppm <sub>vol</sub> |
| Accuracy (CO <sub>2</sub> ) | ±30 ppm ±3% of reading                                    |
| Dimensions [mm]             | 125 x 85 x 22   |
| Dimensions display [mm]     | 49 x 37   |
| Life expectancy             | >15 years   |
| Operation temperature range | 0–50°C  |
| Power supply                | 12VDC, 24VAC/DC   |
| Communication               | Modbus (MB) or BACnet (BAC) protocol over RS485           |

## Key benefits

- Maintenance free
- Three sensors in one housing: CO<sub>2</sub>, temp and RH
- Colour touch display with possibility of customisable GUI
- PIN codes for access to display and meter settings
- Improved housing design for effective measurement



**Senseair**

©2019 Senseair AB. All rights reserved.

# tSENSE (Disp) Technical Specification

## General Performance:

|                                   |   |
|-----------------------------------|---|
| Storage Temperature Range         | -30–70°C  |
| Sensor Life Expectancy            | >15 years   |
| Maintenance Interval <sup>1</sup> | Maintenance free  |
| Self-Diagnostics                  | Complete function-check of the sensor module  |
| Display (Disp)                    | Configurable colour LCD with CO <sub>2</sub> [ppm], Temperature [°C] and Humidity [%RH] |
| Buttons                           | Touch display (Disp)  |
| Warm-up Time                      | ≤1min.(@ full specs 15min )   |
| Operating Temperature Range       | 0–50°C  |
| Operating Humidity Range          | 0–95%RH, non condensing humidity environment  |
| Operating Environment             | Residential, commercial   |

## Electrical / Mechanical:

|                        |   |
|------------------------|---|
| Power Input            | 12VDC, 24VDC or 24VAC (50–60Hz) ±20%  |
| Power Consumption      | <0.35W average non-display version, <0.6W display version   |
| Peak Power Consumption | <2W   |
| Wiring Connections     | Screw terminal, max 1.5mm <sup>2</sup> , Containing: Power, GND, Out1, Out2, Out3, RS485.<br>Option: passive temperature or relay |

## CO<sub>2</sub> Measurement:

|                       |  |
|-----------------------|--|
| Sensing Method        | Non-dispersive infrared (NDIR) waveguide technology  |
| Sampling Method       | Diffusion  |
| Response Time (T1/e)  | <3min  |
| Measurement Range     | 0–2000ppm <sub>vol</sub>   |
| Accuracy <sup>2</sup> | ±50ppm (@1000ppm <sub>vol</sub> , 17–28°C and 30–60%RH)<br>Typical full range: ±30ppm +3% of measured value <sup>3,4</sup> |
| Pressure Dependence   | +1.58% reading per kPa deviation from normal pressure, 101.3kPa  |
| Measurement Interval  | 15s  |

## Temperature Measurement:

|                       |   |
|-----------------------|---|
| Measurement Range (T) | 0–50°C                                      |
| Accuracy <sup>5</sup> | ±0.5°C (@ 17–28°C), ±1.0°C (outside 0–50°C) |
| Repeatability         | ±0.25°C (@ 17–28°C)                         |
| Response Time         | <6min (Air velocity of 0.15m/s)             |
| Measurement Interval  | 15s   |

## Relative Humidity Measurement:

|                       |                                 |
|-----------------------|---------------------------------|
| Measurement Range     | 0–100%RH                        |
| Accuracy <sup>5</sup> | ±5%RH (@ 20–80%RH)              |
| Hysteresis            | ±1%RH (@ 20–80%RH)              |
| Annual Drift          | <±0.5%RH                        |
| Repeatability         | ±0.25%RH (@ 17–28°C)            |
| Response Time         | <6min (Air velocity of 0.15m/s) |
| Measurement Interval  | 15s                             |

## Outputs:

### Linear Analog Outputs:

|   |   |
|---|---|
| Protection                                | PTC-fuses (auto reset), short-circuit safe                          |
| Output Conversion Accuracy                | ±2% of reading ±20mV  |
| Output Signal                             | Voltage output 0–10V, Rout <100Ω, Load: >5kΩ                        |
| Output Resolution                         | 10-bits, 10mV steps, 0.1% steps of full ppm/°C/%RH range            |
| Out1: CO <sub>2</sub> <sup>6</sup>        | 0–10V, corresponds to 0–2000 ppm <sub>vol</sub> , at screw terminal |
| Out2: Temperature (T) <sup>7</sup>        | 0–10V, corresponds to 0–50°C, at screw terminal                     |
| Out3: Relative Humidity (RH) <sup>7</sup> | 0–10V, corresponds to 0–100%RH, at screw terminal                   |

### Digital Output:

|                         |  |
|-------------------------|--|
| Relay (RL) <sup>6</sup> | On ≥1000 ppm <sub>vol</sub> CO <sub>2</sub> , Off ≤900ppmv <sub>ol</sub> , CO <sub>2</sub> , at screw terminal |
| Input Source            | Form C / DPDT, I <sub>max</sub> : 1A/50VAC/24VDC<br>CO <sub>2</sub> / T / RH (configurable via touch display)  |

Note 1: No maintenance required in normal indoor air as ABC (Automatic Baseline Correction) is used.

Note 2: In normal IAQ applications, accuracy is defined after minimum three (3) ABC-pe riods of continuous operation with ABC.

Note 3: Accuracy is specified over operating temperature range. Specification is refer enced to certified calibration mixtures. Uncertainty of calibration gas mixtures (±1% currently) is to be added to the specified accuracy for absolute measurements.

Note 4: Repeatability is included. Uncertainty of calibration gases (±1%) is added to the specified accuracy.

Note 5: Depending on display brightness setting.

Note 6: Can be configured with PC software UIP (version 5 or later). See information at [senseair.com](http://senseair.com)

# Service van EURO-INDEX

EURO-INDEX verleent service op alle meetinstrumenten uit haar leveringspakket en biedt de faciliteiten, kennis en hoog gekwalificeerd personeel voor (preventief) onderhoud, reparatie en kalibratie van uw meetinstrumenten.

## Geautoriseerd Service Centrum

EURO-INDEX is van alle vertegenwoordigde merken een Geautoriseerd Service Centrum.

Dit betekent dat uw instrumenten worden behandeld door goed opgeleid en kundig personeel, dat beschikt over de juiste gereedschappen en software. Er worden uitsluitend originele onderdelen gebruikt en de garantie van uw instrument, evenals de certificering (ATEX, EN50379, etc.) blijven intact.

## Service- en kalibratielaboratorium

EURO-INDEX beschikt over een bijzonder modern service- en kalibratielaboratorium met RvA accreditatie naar NEN-EN-ISO/IEC 17025. Deze accreditatie geldt voor verschillende grootheden, zoals gespecificeerd in de scope bij accreditatienummer K105.



## KWS®

KWS is een uniek servicesysteem voor uw meetinstrumenten met periodiek onderhoud en kalibratie. Veel zaken worden voor u geregeld, zodat u zonder zorgen gebruik kunt maken van uw meetinstrumenten. De kosten zijn laag en voorspelbaar.

## Digitale toegang tot uw kalibratiecertificaten met Mijn KWS

Via het Mijn KWS webportal heeft u altijd en overal toegang tot uw kalibratiecertificaten en gerelateerde documenten.

## Verhuur van meetinstrumenten

- Uitgebreid assortiment
- Deskundig advies
- Instrumenten worden geleverd met accessoirepakket en herleidbaar kalibratiecertificaat

## EURO-INDEX Academy

- Producttrainingen (individueel en klassikaal)
- Seminars
- Demonstratie- en instructievideo's

Bekijk de video op ons YouTube kanaal en ontdek alles over KWS



Servicebalie



Kalibratie rookgasanalyse



Seminars en workshops



Kalibratie thermografie

Wijzigingen voorbehouden EURO-INDEX® VL 18001

Het Bluetooth® woord- en beeldmerk zijn eigendom van Bluetooth SIG, Inc. Gebruik van deze merken door EURO-INDEX geschiedt onder licentie.



**BELGIË**  
Leuvensesteenweg 607  
1930 Zaventem  
T: 02 - 757 92 44  
F: 02 - 757 92 64  
info@euro-index.be  
www.euro-index.be

**NEDERLAND**  
Rivium 2e straat 12  
2909 LG Capelle a/d IJssel  
T: +31 - (0)10 - 2 888 000  
F: +31 - (0)10 - 2 888 010  
verkoop@euro-index.nl  
www.euro-index.nl

